

Certificate of Compliance

Certificate Number **20070718 – E240314A**
Report Reference **E240314, 2003 December 12**
Issue Date **2007 July 18**

Page 1 of 1



**Underwriters
Laboratories Inc.®**

Issued to: **CENTELSA**

CALLE 10 NO 38-43
URB ACOPI YUMBO
APDO 2332
CALI, COLOMBIA

*This is to certify that
representative samples of*

Instrumentation Tray Cable

Instrumentation Tray Cable, Type ITC.

*Have been investigated by Underwriters Laboratories Inc.® in accordance
with the Standard(s) indicated on this Certificate.*


Standard(s) for Safety:

**The basic standard used to investigate products in this category is
ANSI/UL 2250, "Instrumentation Tray Cable."**

Additional Information:

None

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Tiffany Ladage*
Tiffany Ladage, Customer Service Specialist
Underwriters Laboratories Inc.

Reviewed by: *Roger Herb*
Roger Herb, Staff Engineer
Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL

For questions in The United States of America you may call 1-877-UL-HELPS.