

CERTIFICATE OF COMPLIANCE

Certificate Number 20160816-E485169
Report Reference E485169-20060801
Issue Date 2016-AUGUST-16

Issued to: CENTELSA
CALLE 10 NO 38-43
URB ACOPI YUMBO
APDO 2332
CALI COLOMBIA

**This is to certify that
representative samples of** POWER-LIMITED FIRE ALARM CABLE
Types FPL, FPLR and FPLP (60°C)

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1424, Cables for Power-Limited Fire-Alarm Circuits
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

